

Management Summary

and

Reporting Memo

on Verification Observations on Landis+Gyr Testing Report

Author:	Client / contact:
Reliability Core Team	Bert van Creij
Holland Innovative	Liander
Sept-Oct 2017	Sept-Oct 2017

DISCLAIMER:

Aan deze uitspraken in dit document kunnen geen rechten worden ontleend. Deze uitspraken zijn gebaseerd op de informatie zoals verstrekt door externe partijen. Holland Innovative B.V. heeft deze data naar beste kunnen verwerkt, maar kan geen verantwoordelijkheid of aansprakelijkheid aanvaarden voor de verstrekte informatie, noch voor het gebruik daarvan of voor enig verlies dat daaruit zou kunnen voortvloeien.

Dit document, ongeacht de verschijningsvorm, mag niet worden gepubliceerd, gereproduceerd, getransporteerd, opgeslagen of gedistribueerd.

Holland Innovative B.V. behoudt zich het recht voor deze disclaimer te allen tijde met onmiddellijke ingang en zonder kennisgeving vooraf te wijzigen.



Focus on complex business processes

www.holland-innovative.nl

Contents

MANAGEMENT SUMMARY	3
1. OPDRACHTOMSCHRIJVING	3
1.1 OPDRACHTOMSCHRIJVING LIANDER.....	3
1.2 REFERENTIES.....	3
1.3 REPORTING MEMO	3
2. MANAGEMENT SUMMARY.....	4
2.1 LANDIS+GYR – Onderzoek en Testen van Bosses	4
2.2 Aanbevelingen Use Case en Uitgangspunten	4
REPORTING MEMO – VERIFICATION OBSERVATIONS ON LANDIS+GYR TESTING REPORTS	5
3. REPORTING MEMO.....	5
3.1 REPORTING MEMO OVERVIEW.....	5
3.2 RELATED DOCUMENTS	5
4. REPORTING MEMO – VERIFICATION OBSERVATIONS ON LANDIS+GYR TESTING REPORTS	6
4.1 GENERAL VERIFICATION OBSERVATIONS.....	6
4.2 VERIFICATION OBSERVATIONS ON “HALT – VIBRATION PROFILING”	7
4.3 VERIFICATION OBSERVATIONS ON “HALT – TCVIB”	7
4.4 VERIFICATION OBSERVATIONS ON “DOE – DEFERRED THREADS”	9
4.5 VERIFICATION OBSERVATIONS ON “DOE – METER FAILURE”	9
4.6 VERIFICATION OBSERVATIONS ON “DOE – REDUCED TORQUE”.....	10
4.7 VERIFICATION OBSERVATIONS ON “DOE – MANIFOLD DEGRADATION”	10
4.8 VERIFICATION OBSERVATIONS ON “DSMR4 AND SMR5 EURO METERS – DEFERRED THREAD RELIABILITY TEST – SUMMARY REPORT – OVERALL RESULTS – NEED TO EXPAND”	11



Management Summary

1. Opdrachtomschrijving

1.1 Opdrachtomschrijving Liander

De opdracht zoals gesteld door Liander aan Holland Innovative B.V. betrof het *verifiëren middels observerend reviewen* van een test rapport van leverancier Landis+Gyr, referentie [1], gedateerd 21-Sept-2017. Andere activiteiten zoals validatie, opstellen van testplannen, uitvoeren van testen, (statistische of fysieke) analyses, of verdere onderzoeken of conclusies door Holland Innovative vormden nadrukkelijk en expliciet GEEN deel van deze opdracht.

1.2 Referenties

Ref [1] Report name and number: Not explicitly available. Filename: Infield test report 21 9 17.docx. (First) Report header: *DSMR4 AND SMR5 EURO METERS - DEFERRED THREAD TESTS - OVERALL SUMMARY REPORT*. Date according to report: 19-Sept-2017, Date according to file: 21-Sept-2017. Authors/contributors: Landis+Gyr – David Ballantine, Richard Brighton, Tony Waters. Confidential.

De referenties (documenten) gebruikt tijdens het observerend reviewen van het Landis+Gyr test rapport ten behoeve van verificatie worden benoemd in het 'reporting memo' welke daarbij is opgesteld.

1.3 Reporting Memo

Het gevraagde *verifiëren middels observerend reviewen* is gerapporteerd aan Liander middels een 'reporting memo', welke de 'Verification observations' heeft benoemd per test zoals uitgevoerd door Landis+Gyr, evenals de 'Verification observations' op de 'results and conclusions' zoals gesteld door Landis+Gyr. De 'recommendations' van Landis+Gyr (NB deze zijn op een later moment door Landis+Gyr aangevuld) vielen hierbij buiten de scope van de opdracht.

Dit 'reporting memo' is aangevuld met een Management Summary.

2. Management Summary

2.1 Landis+Gyr – Onderzoek en Testen van bosses

Gebruikmakend van de use case en uitgangspunten en beschikbare informatie van de Netbeheerders heeft Landis+Gyr een onderzoek uitgevoerd naar mogelijke lekkage op de boss-nut-verbinding van de DSMR4 en SMR5 gasmeters met KZ manifolds in het veld gedurende de levensduur.

De gegeven use case bevat o.a.:

- Beperkte informatie over de gebruiksomstandigheden en bijbehorende invloedfactoren.
- Beperkte informatie over opgetreden issues in het veld, historische kwantitatieve data ontbreekt.
- Geen kwantitatieve eis welke aangetoond diende te worden.

Binnen dit kader heeft Landis+Gyr geprobeerd een mogelijk verschil in leak performance aan te tonen tussen gasmeters met zgn. ‘bosses with deferred threads’ en gasmeters met ‘bosses with standard threads’ zoals verbonden met de manifolds. De dimensies van ‘bosses with deferred threads’ betreffen de maximaal gevonden afwijking. Deze dimensie afwijking is gebaseerd op de beperkt beschikbare productie data van de Landis+Gyr bosses. De aannames van Landis+Gyr hierbij betreffen het faalgedrag (faalmechanisme) van boss-nut-verbinding en de invloedfactoren. Andere risico’s zoals andere faalmechanismes, andere invloedfactoren, of andere lekkage locaties zijn niet in de scope meegenomen door Landis+Gyr.

In verband met de beperkte hoeveelheid beschikbare tijd en test samples is gekozen de testen middels een Highly Accelerated Life Testing principe uit te voeren. Daardoor kan er geen gebruik gemaakt worden van een volledige use case. Tevens is een valide statistische onderbouwing door de beperkte steekproefgrootte niet mogelijk.

Concluderend kan op basis van de resultaten van dit onderzoek gesteld worden dat met de beschikbare data en informatie het niet mogelijk is om de uitspraak te doen dat de meter populatie met ‘bosses with standard threads’ en de meter populatie met ‘bosses with deferred threads’ significant verschillend zijn ten aanzien van de geteste lekkage criteria. Hierbij moet worden opgemerkt dat de beschikbare use case informatie en de gestelde randcondities/uitgangspunten grote invloed kunnen hebben op zowel het onderzoek als de uitgevoerde testen. Variaties door productie, installatie en gebruik (use case) kunnen grote invloed hebben op dit issue en op het onderzoek.

2.2 Aanbevelingen Use Case en Uitgangspunten

De Netbeheerders hebben ettelijke uitgangspunten en criteria beschikbaar gesteld voor de use case voor het onderzoek. Teneinde deze use case volledig te maken, opgesteld conform industry-best-practice, worden de volgende aanvullingen aanbevolen voor een use case definitie:

- Definitie van de reliability requirements voor dit issue.
- Definitie van de Critical To Quality van dit issue – lekkage en locatie.
- Data en informatie over issues in het veld, historische data, omvang van het risico.
- Informatie over gebruikscondities en koppeling met de use case beschrijving van het product.
- Installatie proces, metingen ter plekke, met bijbehorende specificaties en testen.
- Productie proces, specificaties en kennis van procesvariatie(s).
- Assessment van risico’s behorende bij de reliability requirements.

Reporting memo – Verification Observations on Landis+Gyr Testing reports

3. Reporting Memo

3.1 Reporting Memo Overview

This reporting memo re-iterates the verification observations based upon Landis+Gyr Testing Report, with respect to Gas meters with Deferred threads combined with KZ manifolds.

The verification observations are on the specific tests as described in the Landis+Gyr report. The verification observations are summarized per test, with additional verification observations on the Landis+Gyr conclusions and the Landis+Gyr overall summaries.

3.2 Related documents

The Landis+Gyr Testing Report and associated documents written and used, upon which this reporting memo is based:

- Report name: Not explicitly available. Filename: Infield test report 21 9 17.docx. Report header: *DSMR4 AND SMR5 EURO METERS - DEFERRED THREAD TESTS - OVERALL SUMMARY REPORT*.
- Document name: Not explicitly available. Filename: (A) DSMR SMR5 - TCVIB (Reduced Thread and Good Meters) - Master Sheet -xlsx.
- Document name: AN ENGINEERING REPORT for LANDIS AND GYR LIMITED, HALT OF G350-3455 AND G350-5455 GAS METERS, REPORT NO. TRA-010109-21-CR-01A, SEPTEMBER 2012. Filename: DSMR4 HALT REPORT TRaC TRA-010109-21-CR-01A.PDF
- Document name: FAILURE ANALYSIS, Rapport n° / Report number : FA-12-0346-FIN-001, Sept 2012, by Presto Engineering. Filename: FA-12-0346-FIN-001.pdf
- Document name: HALT Testing For Landis+Gyr Ltd On G4 and G6 Gas Meter, Report No. TRA-028984-21-CR-01A, NOVEMBER 2015, by Element Materials Technology. Filename: TRA-028984-21-CR-01A.PDF
- Document name: HALT Test Plan For Landis+Gyr Ltd. On G4 and G6 Gas Meter, Report No. TRA-028984-21-TP-01A, 15 OCT 2015, by Element Materials Technology. Filename: TRA-028984-21-TP-01A.PDF



4. Reporting memo – Verification Observations on Landis+Gyr Testing reports

The verification observations are summarized per test, with additional verification observations on the conclusions and overall summaries. Specifically:

- General verification observations, on conclusions and summaries
- Verification observations on “HALT – Vibration profiling”
- Verification observations on “HALT – TCVIB”
- Verification observations on “DoE – Deferred Threads”
- Verification observations on “DoE – Meter Failure”
- Verification observations on “DoE – Reduced Torque”
- Verification observations on “DoE – Manifold Degradation”
- Verification observations on “DSMR4 and SMR5 Euro meters - deferred thread reliability test - summary report - overall results – need to expand”

4.1 General verification observations

The approach seems to be based upon ‘learning by doing’ and no clear structure or process or (statistical) substantiation has been defined and agreed upon on beforehand.

Most statements are given as conclusions from a test on multiple occasions, while they are not and cannot solely based on that test.

Moreover, often the statement itself is not proven but also “it cannot be proven that the opposite of that statement is true”. This is also seen in the usage of the wording ‘proves’ instead of ‘shows’/‘indicates’.

Details ('proof') of the gas leakage having occurred in the field - including how, where, number of occurrences, leak location on meter, when, population, failure modes/mechanism, conditions, etc. - have not been provided.

The relationship with design and process risk assessments has not been clarified nor made available.

A revision history plus clear traceability of the Landis+Gyr reporting is not available, and some references and background reports are missing.

Pass/Fail criteria of the leak test do not detail the leak location on the meter/manifold combination and how is proven (tested) that no other leaks (and/or other locations than the relevant location) have occurred.

The term DoE is used while the tests executed are set up as experiments without a DoE (Design-of-Experiments) structure or approach (DfSS – Design-for-Six-Sigma, DfR – Design-for-Reliability).

4.2 Verification observations on "HALT – Vibration profiling"

What the test will prove with respect to leaks or leak tests has not been defined a priori (before the test). No failures (leaks) have been observed during the test while the initial set-up was a destructive test so failures had to be induced. So, when no failures are observed, the test is not harsh enough (different chamber needed to exhibit higher stress levels?) or does not encompass all relevant stressors.

With respect to the failures focused upon: leak tightness – which location ? Connection of the meter – which connection(s)? The health check (equal to finding functional failures?) has only been done after the test has been finished – in case of a fail, no additional relevant info could have been gathered.

Pressure levels were measured at 0 min, 1 min, and 5 min, to find leaks. Criterion: when pressure level dropped more than 1 mBar, then leakage. In the provided datasheets of the tests, for both deferred and good meters: the pressure levels sometimes went up during the 5-min measurement – without explanation. The measurement did not include indication of accuracy of measuring pressures, apparently measured in units of 0.1 mBar – plus no MSA (GR&R) provided. Some pressure drops of 0.9 mBar observed which might be 1 mBar thus leak when indication of measurement accuracy and R&R available.

Comparison of HALT Grms levels to natural phenomena such as earth quakes does not add to the significance of the test or its outcome.

4.3 Verification observations on "HALT – TCVIB"

The statement "The test showed there was no difference between standard and deferred meters." has not been (*statistically*) proven. On beforehand, no confidence or test set-up basis has been provided (why 2x4 for both bosses). It can be said that "It has not been proven that there is a (positive or negative) difference between deferred and standard threads with respect to leaks at XYZ location" – this should however NOT be translated as "So the standard and deferred bosses are proven the same".


The statement "The test did show that the nut to boss joint was the weakest in respect to leaking" is not substantiated, for example by finding other leak locations (internal or external) failing sooner in the same test.


The statement on "functionally failing before leakage": see later in memo at relevant DoE.

Pass/Fail criteria of the leak test do not detail the leak location on the meter/manifold combination and how is proven (tested) that no other leaks (and/or other locations than the relevant boss/nut location) have occurred.

No relationship between degrees loosening / tightening and its progression throughout the test and leakage is observed.

The statement that the tightening torque increased as the test progresses cannot be statistically proven, see graphs (next page) with the measured torques (shown in Landis+Gyr table) – no trends upwards or downwards can be observed. The measurement system has not been analyzed by Landis+Gyr with respect to systematic and random error, and the measured torques are depicted as integer (no decimals). In addition, Two-sample T-tests show no significant difference 'over time' between the measured torques throughout the tests progressing. Also, regression lines did not show significant correlation between test progression and measured torques ($R^2 < 20\%$).





4.4 Verification observations on "DoE – Deferred Threads"

The statement "Increased deferred threads perform the same as standard bosses." has not been (*statistically*) proven – the test did not show proof (could not provide proof) of a difference between standard threads and deferred threads that have been tightened.

The statement "This shows that once the nut is engaged and correctly tightened it has the same strength and leak integrity to that of standard threads." should refer to installation procedures with respect to tightening torque, validation, measurement, assurance, etc. since it states '*correctly tightened*'.

4.5 Verification observations on "DoE – Meter Failure"

The statement "From this we can conclude that the meters will fail operationally before there is a leak from the boss and nut" has not been proven since the accumulated damage built up by the electronics (functional components) due to the elevated stresses might very well be different (so also: much larger) than the damage accumulated by the mechanical joints due to the same stresses. (Translated: when this would be set up as an ALT, then the Acceleration Factor would be different for the electronics than for the mechanical nut-boss joint (different failure mechanism, different life-stress model, different Acceleration Factor)).

4.6 Verification observations on "DoE – Reduced Torque"

The meters were tested using possibly degraded manifolds – latter as stated later on. This implies that the test cannot distinguish between the loosening of the nuts being due to the tightening or due to the manifolds. Also, loosening of the nut (other than complete detachment) has not been quantitatively correlated to leakage, so the effect of tightening torque on leakage (risk, probability, frequency) cannot be quantified nor proven. Tightening torque seems a factor, but the criticality of this factor nor the sensitivity of leakage thereto has not been analyzed nor proven.

4.7 Verification observations on "DoE – Manifold degradation"

The statement "The following tables clearly demonstrates the increased amount of movement and leakages as the test progressed, when compared to the earlier tests" is based upon 4 meters – 2 meters had leakage, same amount as earlier test – nut movement of these 4 meters do not seem to follow a trend or clear pattern (loosen, tighten, loosen again, all between cycles), compared to earlier tests. Too small sample size to prove degradation, which also makes 'clearly demonstrates' less clear.



4.8 Verification observations on "DSMR4 and SMR5 Euro meters - deferred thread reliability test - summary report - overall results – need to expand"

The results as stated have been discussed in the previous verification observations. In overview re-iterated:

- Statement "No difference in leakage performance between standard and deferred meters" has not been proven – nor has the opposite statement (negative of original) been proven, see paragraph 2.3
- Statement "Meters will functionally fail before leaks occur" has not been proven – nor has the opposite statement (negative of original) been proven, see paragraph 2.5
- Statement "Meters with excessive deferred threads cannot be fitted" should refer to dimensions (thread, etc.) and to installation procedures, see also paragraph 2.4.
- Statement "It required considerable force to induce movement and leakage of the nut to boss" seems to be based upon practical experiences throughout the tests.
- Statement "The tightening torque is a critical factor to the strength of the nut / boss joint" has not been proven quantitatively with respect to criticality and sensitivity, see paragraph 2.6
- Statement "The manifolds and manifold nuts wear through testing" – evidence is qualitatively shown using a small sample size.
- Statement "Boss & nut is the weakest element of the meter & manifold system with respect to leakages" has not been proven – nor has the opposite statement (negative of original) been proven, see paragraph 2.3